

OCCUPANCY SENSORS SELECTION GUIDE

Occupancy sensors can automatically turn lights on when you enter a room and off when unoccupied. Ideal for intermittently occupied spaces in commercial, industrial and office applications. Motion sensors are maintenance free, conserve energy and save money when illumination isn't necessary.

When choosing a sensor, the following criteria needs to be taken into consideration : ceiling heights, dry/wet location, temperature, applications and other additional options.

SENSORS TECHNOLOGY



PIR *technology*

PIR sensors detect the heat emitted by humans in motion when entering a space. These sensors cannot see through or around obstacles and have limited sensitivity to minor movements.

A type of occupancy sensor that uses thermal detectors to absorb the received energy focused on them. When a person moves into or out of a field of view, the detector experiences a change in received energy, which is converted into an electrical signal. The detector aperture is converted optically, by a multi-segmented, Fresnel lens array into multiple discrete fields of view that are strategically located throughout the occupancy sensor pattern. PIR sensors detect body heat if the ambient environment of the sensing area is near the temperature of the human body, so they are less likely to perform at their peak.

Pros

- Consume less energy than other types of sensors
- There is no electromagnetic interference (RFI/EMI)

Cons

- Detection can be fooled by someone moving very fast or very slowly.
- They are not ideal in harsh environments where heat cycles are not regular.
- They are vulnerable in areas where there is smoke and/or dust.
- They are often integrated outside a lighting fixture.



high frequency *technology*

High frequency sensors use a Doppler Effect to detect minor movements. These sensors emit pulses of specific microwave frequencies that go through most building materials, but not through metal.

A type of sensor that emits a low power microwave into the area being monitored. Changes in the reflection pattern caused by motion are received by the sensor and converted into an electrical signal. These sensors cover a larger area than infrared sensors. Microwave sensors use a Doppler Effect to detect motion even when completely concealed behind non-metallic materials without interference from temperature.

Pros

- There are no line of sight issues; they can detect movement around the corner through most building materials.
- They are often integrated within a lighting fixture.
- They can be selected in harsh environment applications where heat cycles are not regular.

Cons

- They can trigger a false alarm caused by slight vibrations.
- They cannot detect movement through metal or thicker brick walls.

Please refer to the following occupancy sensors selection guide to see preset options. Select the desired sensor option and add it to the ordering guide. You can also see all features available for each sensor.

Preset Options		All features available
Sensor option	Features	
VT2, VT4, VN4, VN8		
OSE-PO-0301	ON/OFF Detection Area: 100% Hold time: 20 min	External PIR - ON/OFF, 120-347 V, 20-40' ceiling heights, -10°C to 70°C, Dry and cold location
OSE-PO-0501	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately
OSE-PO-0502	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux No remote capabilities	
OSE-PO-0701	ON/OFF Detection Area: 100% Hold Time: 15 min	External PIR - ON/OFF, 120-277 V, 20' ceiling heights, -40°C to 70°C, Wet location and cold location
OSE-PO-0801	ON/OFF Detection Area: 100% Hold Time: 15 min	External PIR - ON/OFF, 347 V, 20' ceiling heights, -40°C to 70°C, Wet location and cold location
VN4-L, VN8-L		
OSE-PO-0301	ON/OFF Detection Area: 100% Hold time: 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, -10°C to 70°C, Dry and cold location
OSE-PO-0501	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately
OSE-PO-0502	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux No remote capabilities	
OSE-PO-0701	ON/OFF Detection Area: 100% Hold Time: 15 min	External PIR - ON/OFF, 120-277 V, 20' ceiling heights, -40°C to 70°C, Wet location and cold location
OSE-PO-0801	ON/OFF Detection Area: 100% Hold Time: 15 min	External PIR - ON/OFF, 347 V, 20' ceiling heights, -40°C to 70°C, Wet location and cold location
OSE-PB-0202	Bi-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 40% Daylight min level: Disable Remote capabilities	External PIR - Bi-Level, Hold-Off daylight level, 120-347 V, 20' ceiling heights, -40°C to 75°C, Wet location and cold location Remote OSI-FSIR-100 to be ordered separately
OSI-FO-0301	ON/OFF Detection Area: 100% Hold Time: 20 min Daylight min level: Disable	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level, 120-277 V, Max 32' ceiling heights, -25°C to 60°C, Dry and cold location
OSI-FB-0301	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Daylight min level: Disable	
OSI-FB-0302	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 10% Daylight min level: Disable	
OSI-FB-0303	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 50% Daylight min level: Disable	
OSI-FT-0301	Tri-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Stand-by Period: 10 min Daylight min level: Disable	
		Detection Area: 100% Hold Time: 30 sec to 20 min
		Detection Area: 100% Hold Time: 5 min / 10 min / 15 min / 20 min / 30 min Remote Control: 1 min to 30 min Daylight min level: 10 lux to 3000 lux Remote Control: 10 lux to 3000 lux, disable
		Detection Area: 100% Hold Time: 15 sec to 30 min
		Detection Area: 100% Hold Time: 15 sec to 30 min
		Detection Area: 100% Hold Time: 30 sec to 20 min
		Detection Area: 100% Hold Time: 5 min / 10 min / 15 min / 20 min / 30 min Remote Control: 1 min to 30 min Daylight min level: 10 lux to 3000 lux Remote Control: 10 lux to 3000 lux, disable
		Detection Area: 100% Hold Time: 15 sec to 30 min
		Detection Area: 100% Hold Time: 15 sec to 30 min
		Remote control required for other features
		Detection Area: 25%/50%/75%/100% Hold Time: 5s/30s/90s/3 min/20 min/∞ Stand-by Dim Level: 10%/20%/30%/50% Stand-by Period: 0s/5s/5 min/10 min/30 min/1h/∞ Daylight min level: 5 lux/15 lux/30 lux/50 lux/100lu/150 lux/Disable

Sensor option		Preset Options	All features available
		Features	
VN4-L, VN8-L (cont'd)			
OSE-FB-0402	Bi-Level Detection Area : 100% Hold Time : 20 min Stand-by Dim Level : 30% Daylight min level : 50 lux Remote capabilities	External High Frequency - Bi-Level, Tri-Level, Hold-Off daylight level 120-347 V, Max 50' ceiling heights, -35°C to 55°C, Wet and cold location Remote 68681 to be ordered separately	Detection Area: 50%/100% <i>Remote Control:</i> 50%/100% Hold Time: 5s/30s/1 min/3 min/20 min/30 min <i>Remote Control:</i> 5s/30s/1 min/3 min/5 min/10 min/ 20 min/30 min Stand-by Dim Level: 10%/20%/30%/50% <i>Remote Control:</i> 10%/20%/30%/50% Stand-by Period: 0s/1 min/3 min/10 min/30 min/Disable <i>Remote Control:</i> 0s/10s/1 min/3 min/5 min/10 min/ 30 min/Disable Daylight min level: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable <i>Remote Control:</i> 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable
OSE-FT-0402	Tri-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 30% Stand-by Period : 10 min Daylight min level : 50 lux Remote capabilities		
OSI-FO-0601	ON/OFF Detection Area : 100% Hold Time : 30 min Daylight min level : Disable Remote capabilities	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level 120-347 V, Max 25' ceiling heights, -35°C to 70°C, Dry and cold location Remote 68681 to be ordered separately	Detection Area: 25%/50%/75%/100% <i>Remote Control:</i> 25%/50%/75%/100% Hold Time: 8s/30s/1 min/5 min/10 min/15 min/ 30 min <i>Remote Control:</i> 8s/1 min/5 min/15 min/30 min Stand-by Dim Level: 10%/20%/30%/40% <i>Remote Control:</i> 10%/20%/30%/40%/ 50% Stand-by Period: 0s/1 min/3 min/5 min/10 min/ 30 min/∞ <i>Remote Control:</i> 0s/1 min/5 min/30 min/∞ Daylight min level: 5 lux/15 lux/30 lux/50 lux/100lu/150 lux/Disable <i>Remote Control:</i> 5 lux/15 lux/50 lux/150 lux/ Disable
OSI-FO-0602	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : Disable Remote capabilities		
OSI-FO-0603	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 100 lux Remote capabilities		
OSI-FB-0603	Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 40% Daylight min level : Disable Remote capabilities		
OSI-FB-0604	Bi-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 40% Daylight min level : Disable Remote capabilities		
OSI-FB-0605	Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 30% Daylight min level : Disable Remote capabilities		
OSI-FB-0606	Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 10% Daylight min level : Disable Remote capabilities		
OSI-FT-0601	Tri-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 30% Stand-by Period : 10 min Daylight min level : Disable Remote capabilities		
VT2-L			
OSE-PO-0301	ON/OFF Detection Area : 100% Hold time : 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, -10°C to 70°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0501	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately	Detection Area: 100% Hold Time: 5 min/10 min/15 min/20 min/30 min <i>Remote Control:</i> 1 min to 30 min Daylight min level: 10 lux to 3000 lux <i>Remote Control:</i> 10 lux to 3000 lux, disable
OSE-PO-0502	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 3 000 lux No remote capabilities		
OSE-PO-0701	ON/OFF Detection Area : 100% Hold Time : 15 min	External PIR - ON/OFF, 120-277 V, 20' ceiling heights, -40°C to 70°C, Wet location and cold location	Detection Area: 100% Hold Time: 15 sec to 30 min
OSE-PO-0801	ON/OFF Detection Area : 100% Hold Time : 15 min	External PIR - ON/OFF, 347 V, 20' ceiling heights, -40°C to 70°C, Wet location and cold location	Detection Area: 100% Hold Time: 15 sec to 30 min

Preset Options		All features available
Sensor option	Features	
VT2-L (cont'd)		
OSI-F0-0301 ON/OFF Detection Area : 100% Hold Time : 20 min Daylight min level : Disable	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level, 120-277 V, Max 32' ceiling heights, -25°C to 60°C, Dry and cold location	Detection Area: 25%/50%/75%/100% Hold Time: 5s/30s/90s/3 min/20 min/∞ Stand-by Dim Level: 10%/20%/30%/50% Stand-by Period: 0s/5s/5 min/10 min/30 min/1h/∞ Daylight min level: 5 lux/15 lux/30 lux/50 lux/100lu/150 lux/Disable
OSI-FB-0301 Bi-Level Detection Area : 100% Hold Time : 20 min Stand-by Dim Level : 30% Daylight min level : Disable		
OSI-FB-0302 Bi-Level Detection Area : 100% Hold Time : 20 min Stand-by Dim Level : 10% Daylight min level : Disable		
OSI-FB-0303 Bi-Level Detection Area : 100% Hold Time : 20 min Stand-by Dim Level : 50% Daylight min level : Disable		
OSI-FT-0301 Tri-Level Detection Area : 100% Hold Time : 20 min Stand-by Dim Level : 30% Stand-by Period : 10 min Daylight min level : Disable		
OSE-FB-0402 Bi-Level Detection Area : 100% Hold Time : 20 min Stand-by Dim Level : 30% Daylight min level : 50 lux Remote capabilities	External High Frequency - Bi-Level, Tri-Level, Hold-Off daylight level 120-347 V, Max 50' ceiling heights, -35°C to 55°C, Wet and cold location Remote 68681 to be ordered separately	Detection Area: 50%/100% Remote Control: 50%/100% Hold Time: 5s/30s/1 min/3 min/20 min/30 min Remote Control: 5s/30s/1 min/3 min/5 min/10 min/ 20 min/30 min Stand-by Dim Level: 10%/20%/30%/50% Remote Control: 10%/20%/30%/50% Stand-by Period: 0s/1 min/3 min/10 min/30 min/Disable Remote Control: 0s/10s/1 min/3 min/5 min/10 min/ 30 min/Disable Daylight min level: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable Remote Control: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable
OSE-FT-0402 Tri-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 30% Stand-by Period : 10 min Daylight min level : 50 lux Remote capabilities		
OSI-F0-0601 ON/OFF Detection Area : 100% Hold Time : 30 min Daylight min level : Disable Remote capabilities	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level 120-347 V, Max 25' ceiling heights, -35°C to 70°C, Dry and cold location Remote 68681 to be ordered separately	Detection Area: 25%/50%/75%/100% Remote Control: 25%/50%/75%/100% Hold Time: 8s/30s/1 min/5 min/10 min/15 min/ 30 min Remote Control: 8s/1 min/5 min/15 min/30 min Stand-by Dim Level: 10%/20%/30%/40% Remote Control: 10%/20%/30%/40%/ 50% Stand-by Period: 0s/1 min/3 min/5 min/10 min/ 30 min/∞ Remote Control: 0s/1 min/5 min/30 min/∞ Daylight min level: 5 lux/15 lux/30 lux/50 lux/100lu/150 lux/Disable Remote Control: 5 lux/15 lux/50 lux/150 lux/ Disable
OSI-F0-0602 ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : Disable Remote capabilities		
OSI-F0-0603 ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 100 lux Remote capabilities		
OSI-FB-0603 Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 40% Daylight min level : Disable Remote capabilities		
OSI-FB-0604 Bi-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 40% Daylight min level : Disable Remote capabilities		
OSI-FB-0605 Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 30% Daylight min level : Disable Remote capabilities		
OSI-FB-0606 Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 10% Daylight min level : Disable Remote capabilities		
OSI-FT-0601 Tri-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 30% Stand-by Period : 10 min Daylight min level : Disable Remote capabilities		

Preset Options		All features available	
Sensor option	Features		
L1FB			
OSE-PO-0303	ON/OFF Detection Area : 100% Hold Time : 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, With Arm, -10°C to 70°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0304	ON/OFF Detection Area : 100% Hold Time : 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, With Arm, -40°C to 40°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0503	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, With Arm, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately	Detection Area: 100% Hold Time: 5 min/10 min/15 min/20 min/30 min Remote Control: 1 min to 30 min Daylight min level: 10 lux to 3000 lux Remote Control: 10 lux to 3000 lux, disable
OSE-PO-0504	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 3 000 lux No remote capabilities		
OSE-PB-0202	Bi-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 40% Daylight min level : Disable Remote capabilities	External PIR - Bi-Level, Hold-Off daylight level, 120-347 V, 20' ceiling heights, -40°C to 75°C, Wet location and cold location Remote OSI-FSIR-100 to be ordered separately	Remote control required for other features
OSE-F0-0401	ON-OFF Detection Area : 100% Hold Time : 20 min Remote capabilities	External High Frequency - ON-OFF, Bi-Level, Tri-Level, Hold-Off daylight level 120-347 V, Max 50' ceiling heights, -35°C to 55°C, Wet and cold location Remote 68681 to be ordered separately	Detection Area: 50%/100% Remote Control: 50%/100% Hold Time: 5s/30s/1 min/3 min/20 min/30 min Remote Control: 5s/30s/1 min/3 min/5 min/10 min/20 min/30 min Stand-by Dim Level: 10%/20%/30%/50% Remote Control: 10%/20%/30%/50% Stand-by Period: 0s/1 min/3 min/10 min/30 min/Disable Remote Control: 0s/10s/1 min/3 min/5 min/10 min/30 min/Disable Daylight min level: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable Remote Control: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable
OSE-FB-0401	Bi-Level Detection Area : 100% Hold Time : 20 min Stand-by Dim Level : 30% Remote capabilities		
F1FC			
OSE-PO-0303	ON/OFF Detection Area : 100% Hold time : 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, With Arm, -10°C to 70°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0304	ON/OFF Detection Area : 100% Hold Time : 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, With Arm, -40°C to 4°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0503	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, With Arm, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately	Detection Area: 100% Hold Time: 5 min/10 min/15 min/20 min/30 min Remote Control: 1 min to 30 min Daylight min level: 10 lux to 3000 lux Remote Control: 10 lux to 3000 lux, disable
OSE-PO-0504	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 3 000 lux No remote capabilities		
FN			
OSE-PO-0303	ON/OFF Detection Area : 100% Hold Time : 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, With Arm, -10°C to 70°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0304	ON/OFF Detection Area : 100% Hold Time : 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, With Arm, -40°C to 4°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0503	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, With Arm, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately	Detection Area: 100% Hold Time: 5 min/10 min/15 min/20 min/30 min Remote Control: 1 min to 30 min Daylight min level: 10 lux to 3000 lux Remote Control: 10 lux to 3000 lux, disable
OSE-PO-0504	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 3 000 lux No remote capabilities		
OSE-PO-0704	ON/OFF Detection Area : 100% Hold Time : 15 min	External PIR - ON/OFF, 120-277 V, 40' ceiling heights, With Arm, -40°C to 70°C, Wet and cold location	Detection Area: 100% Hold Time: 15 sec to 30 min
OSE-PO-0804	ON/OFF Detection Area : 100% Hold Time : 15 min	External PIR - ON/OFF, 347 V, 40' ceiling heights, With Arm, -40°C to 70°C, Wet and cold location	Detection Area: 100% Hold Time: 15 sec to 30 min

Preset Options		All features available
Sensor option	Features	
FN-L		
OSE-PO-0303	ON/OFF Detection Area: 100% Hold Time: 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, With Arm, -10°C to 70°C, Dry and cold location
OSE-PO-0304	ON/OFF Detection Area: 100% Hold Time: 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, With Arm, -40°C to 4°C, Dry and cold location
OSE-PO-0503	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, With Arm, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately
OSE-PO-0504	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux No remote capabilities	
OSE-PO-0704	ON/OFF Detection Area: 100% Hold Time: 15 min	External PIR - ON/OFF, 120-277 V, 40' ceiling heights, With Arm, -40°C to 70°C, Wet and cold location
OSE-PO-0804	ON/OFF Detection Area: 100% Hold Time: 15 min	External PIR - ON/OFF, 347 V, 40' ceiling heights, With Arm, -40°C to 70°C, Wet and cold location
OSE-PB-0202	Bi-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 40% Daylight min level: Disable Remote capabilities	External PIR - Bi-Level, Hold-Off daylight level, 120-347 V, 20' ceiling heights, -40°C to 75°C, Wet location and cold location Remote OSI-FSIR-100 to be ordered separately
OSI-F0-0301	ON/OFF Detection Area: 100% Hold Time: 20 min Daylight min level: Disable	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level, 120-277 V, Max 32' ceiling heights, -25°C to 60°C, Dry and cold location
OSI-FB-0301	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Daylight min level: Disable	
OSI-FB-0302	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 10% Daylight min level: Disable	
OSI-FB-0303	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 50% Daylight min level: Disable	
OSI-FT-0301	Tri-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Stand-by Period: 10 min Daylight min level: Disable	
OSE-FB-0402	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Daylight min level: 50 lux Remote capabilities	External High Frequency - Bi-Level, Tri-Level, Hold-Off daylight level 120-347 V, Max 50' ceiling heights, -35°C to 55°C, Wet and cold location
OSE-FT-0402	Tri-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 30% Stand-by Period: 10 min Daylight min level: 50 lux Remote capabilities	Remote 68681 to be ordered separately

Preset Options		All features available
Sensor option	Features	
FN-L (cont'd)		
OSI-F0-0601	ON/OFF Detection Area: 100% Hold Time: 30 min Daylight min level: Disable Remote capabilities	<p>Detection Area: 25%/50%/75%/100% Remote Control: 25%/50%/75%/100% Hold Time: 8s/30s/1 min/5 min/10 min/15 min/ 30 min Remote Control: 8s/1 min/5 min/15 min/30 min Stand-by Dim Level: 10%/20%/30%/40% Remote Control: 10%/20%/30%/40%/ 50% Stand-by Period: 0s/1 min/3 min/5 min/10 min/ 30 min/∞ Remote Control: 0s/1 min/5 min/30 min/∞ Daylight min level: 5 lux/15 lux/30 lux/50 lux/100lu/150 lux/Disable Remote Control: 5 lux/15 lux/50 lux/150 lux/ Disable</p>
OSI-F0-0602	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: Disable Remote capabilities	
OSI-F0-0603	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 100 lux Remote capabilities	
OSI-FB-0603	Bi-Level Detection Area: 100% Hold Time: 15 min Stand-by Dim Level: 40% Daylight min level: Disable Remote capabilities	
OSI-FB-0604	Bi-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 40% Daylight min level: Disable Remote capabilities	
OSI-FB-0605	Bi-Level Detection Area: 100% Hold Time: 15 min Stand-by Dim Level: 30% Daylight min level: Disable Remote capabilities	
OSI-FB-0606	Bi-Level Detection Area: 100% Hold Time: 15 min Stand-by Dim Level: 10% Daylight min level: Disable Remote capabilities	
OSI-FT-0601	Tri-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 30% Stand-by Period: 10 min Daylight min level: Disable Remote capabilities	
F2SST, F2CUB, L2WSN, L2CUB		
OSE-PO-0301	ON/OFF Detection Area: 100% Hold time: 20 min	<p>External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, -10°C to 70°C, Dry location</p> <p>Detection Area: 100% Hold Time: 30 sec to 20 min</p>
OSE-PO-0501	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux Remote capabilities	<p>External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, 0°C to 70°C, Dry location</p> <p>Detection Area: 100% Hold Time: 5 min/10 min/15 min/20 min/30 min Remote Control: 1 min to 30 min Daylight min level: 10 lux to 3000 lux Remote Control: 10 lux to 3000 lux, disable</p>
OSE-PO-0502	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux No remote capabilities	<p>Remote OSI-FSIR-100 to be ordered separately</p>
L1PRI		
OSI-PO-0101	ON/OFF Detection Area: 100% Hold Time: 30 min Daylight min level: 100 lux	<p>Internal PIR - ON/OFF, Hold-Off daylight level 120-347 V, 8' ceiling heights, 0°C to 55°C, Dry location</p> <p>Detection Area: 100% Hold Time: 30 sec to 30 min Daylight min level: 100 lux to 1200 lux</p>
L1RTH		
OSE-F0-1001	ON/OFF Detection Area: 100% Hold Time: 20 min Daylight min level: Disable Remote capabilities	<p>External High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level 120-277 V, Max 50' ceiling heights, -35°C to 55°C, Wet location</p> <p>Remote OSI-RC-MH10 to be ordered separately</p> <p>Detection Area: 50% /100% Remote Control: 25%/50%/75%/100% Hold Time: 5s/30s/1 min/3 min/20 min/30 min Remote Control: 5s/30s/1 min/3 min/5 min/10 min/20 min/30 min Stand-by Dim Level: 10%/20%/30%/50% Remote Control: 10%/20%/30%/50% Stand-by Period: 0s/1 min/3 min/10 min/30 min/+∞ Remote Control: 0s/10s/1 min/3 min/5 min/10 min/30 min/+∞ Daylight min level: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/disable Remote Control: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/disable</p>
OSE-FB-1001	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 50% Daylight min level: Disable Remote capabilities	
OSE-F0-1101	ON/OFF Detection Area: 100% Hold Time: 20 min Daylight min level: Disable Remote capabilities	<p>External High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level 347 V, Max 50' ceiling heights, -35°C to 70°C, Wet location</p> <p>Remote OSI-RC-HXGY347 required for other features. To be ordered separately.</p> <p>Detection Area: 25%/50%/75%/100% Hold Time: 5s/30s/1 min/3 min/5 min/10 min/20 min/30 min Stand-by Dim Level: 10%/20%/30%/50% Stand-by Period: 0s/10s/30s/1 min/5 min/10 min/30 min/+∞ Daylight min level: 2 lux/10 lux/30 lux/50 lux 80 lux/120 lux/Disable</p>

Preset Options		All features available
Sensor option	Features	
L2STL		
OSE-PO-0301	ON/OFF Detection Area: 100% Hold time: 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, -10°C to 70°C, Dry location
OSE-PO-0501	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately
OSE-PO-0502	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux No remote capabilities	
OSI-F0-0301	ON/OFF Detection Area: 100% Hold Time: 20 min Daylight min level: Disable	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level 120-277 V, Max 32' ceiling heights, -25°C to 60°C, Dry location
OSI-FB-0301	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Daylight min level: Disable	
OSI-FB-0302	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 10% Daylight min level: Disable	
OSI-FB-0303	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 50% Daylight min level: Disable	
OSI-FT-0301	Tri-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Stand-by Period: 10 min Daylight min level: Disable	
OSI-F0-0601	ON/OFF Detection Area: 100% Hold Time: 30 min Daylight min level: Disable Remote capabilities	
OSI-FB-0601	Bi-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 30% Daylight min level: Disable Remote capabilities	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level, 120-347 V, Max 25' ceiling heights, -35°C to 70°C, Dry location Remote 68681 to be ordered separately
OSI-FB-0602	Bi-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 10% Daylight min level: Disable Remote capabilities	
OSI-FB-0603	Bi-Level Detection Area: 100% Hold Time: 15 min Stand-by Dim Level: 40% Daylight min level: Disable Remote capabilities	
OSI-FB-0604	Bi-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 40% Daylight min level: Disable Remote capabilities	
OSI-FT-0601	Tri-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 30% Stand-by Period: 10 min Daylight min level: Disable Remote capabilities	

Preset Options		All features available	
Sensor option	Features		
VT4-L			
OSE-PO-0301	ON/OFF Detection Area: 100% Hold Time: 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, -10°C to 70°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0302	ON/OFF Detection Area: 100% Hold Time: 20 min	External PIR - ON/OFF 120-347 V, 20-40' ceiling heights, -40°C to 4°C, Dry and cold location	Detection Area: 100% Hold Time: 30 sec to 20 min
OSE-PO-0501	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux Remote capabilities	External PIR - ON/OFF, Hold-Off daylight level 120-347 V, 15-40' ceiling heights, 0°C to 70°C, Dry location Remote OSI-FSIR-100 to be ordered separately	Detection Area: 100% Hold Time: 5 min/10 min/15 min/20 min/30 min <i>Remote Control:</i> 1 min to 30 min Daylight min level: 10 lux to 3000 lux <i>Remote Control:</i> 10 lux to 3000 lux, disable
OSE-PO-0502	ON/OFF Detection Area: 100% Hold Time: 15 min Daylight min level: 3 000 lux No remote capabilities		
OSE-PO-0701	ON/OFF Detection Area: 100% Hold Time: 15 min	External PIR - ON/OFF, 120-277 V, 20' ceiling heights, -40°C to 70°C, Wet and cold location	Detection Area: 100% Hold Time: 15 sec to 30 min
OSI-FO-0301	ON/OFF Detection Area: 100% Hold Time: 20 min Daylight min level: Disable	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level, 120-277 V, Max 32' ceiling heights, -25°C to 60°C, Dry and cold location	Detection Area: 25%/50%/75%/100% Hold Time: 5s/30s/90s/3 min/20 min/∞ Stand-by Dim Level: 10%/20%/30%/50% Stand-by Period: 0s/5s/5 min/10 min/30 min/1h/∞ Daylight min level: 5 lux/15 lux/30 lux/50 lux/100lu/150 lux/Disable
OSI-FB-0301	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Daylight min level: Disable		
OSI-FB-0302	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 10% Daylight min level: Disable		
OSI-FB-0303	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 50% Daylight min level: Disable		
OSI-FT-0301	Tri-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Stand-by Period: 10 min Daylight min level: Disable		
OSE-FB-0402	Bi-Level Detection Area: 100% Hold Time: 20 min Stand-by Dim Level: 30% Daylight min level: 50 lux Remote capabilities	External High Frequency - Bi-Level, Tri-Level, Hold-Off daylight level 120-347 V, Max 50' ceiling heights, -35°C to 55°C, Wet and cold location Remote OSI-RC-MH10 to be ordered separately	Detection Area: 50%/100% <i>Remote Control:</i> 50%/100% Hold Time: 5s/30s/1 min/3 min/20 min/30 min <i>Remote Control:</i> 5s/30s/1 min/3 min/5 min/10 min/ 20 min/30 min Stand-by Dim Level: 10%/20%/30%/50% <i>Remote Control:</i> 10%/20%/30%/50% Stand-by Period: 0s/1 min/3 min/10 min/30 min/Disable <i>Remote Control:</i> 0s/10s/1 min/3 min/5 min/10 min/ 30 min/Disable Daylight min level: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable <i>Remote Control:</i> 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable
OSE-FT-0402	Tri-Level Detection Area: 100% Hold Time: 30 min Stand-by Dim Level: 30% Stand-by Period: 10 min Daylight min level: 50 lux Remote capabilities		

Sensor option		Preset Options	All features available
		Features	
VT4-L (cont'd)			
OSI-F0-0601	ON/OFF Detection Area : 100% Hold Time : 30 min Daylight min level : Disable Remote capabilities	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level 120-347 V, Max 25' ceiling heights, -35°C to 70°C, Dry and cold location Remote 68681 to be ordered separately	Detection Area: 25%/50%/75%/100% Remote Control: 25%/50%/75%/100% Hold Time: 8s/30s/1 min/5 min/10 min/15 min/ 30 min Remote Control: 8s/1 min/5 min/15 min/30 min Stand-by Dim Level: 10%/20%/30%/40% Remote Control: 10%/20%/30%/40%/ 50% Stand-by Period: 0s/1 min/3 min/5 min/10 min/ 30 min/∞ Remote Control: 0s/1 min/5 min/30 min/∞ Daylight min level: 5 lux/15 lux/30 lux/50 lux/100lu/150 lux/Disable Remote Control: 5 lux/15 lux/50 lux/150 lux/ Disable
OSI-F0-0602	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : Disable Remote capabilities		
OSI-F0-0603	ON/OFF Detection Area : 100% Hold Time : 15 min Daylight min level : 100 lux Remote capabilities		
OSI-FB-0603	Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 40% Daylight min level : Disable Remote capabilities		
OSI-FB-0604	Bi-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 40% Daylight min level : Disable Remote capabilities		
OSI-FB-0605	Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 30% Daylight min level : Disable Remote capabilities		
OSI-FB-0606	Bi-Level Detection Area : 100% Hold Time : 15 min Stand-by Dim Level : 10% Daylight min level : Disable Remote capabilities		
OSI-FT-0601	Tri-Level Detection Area : 100% Hold Time : 30 min Stand-by Dim Level : 30% Stand-by Period : 10 min Daylight min level : Disable Remote capabilities		
VTE4-L			
OS1	ON/OFF Detection Area : 100% Hold Time : 20 min Daylight min level : Disable	Internal High Frequency - ON/OFF, Hold-Off daylight level, 120-277 V, Max 50' ceiling heights, -20°C to 60°C	Detection Area: 25%/50%/75%/100% Hold Time: 5s/30s/90s/3 min/20 min/30 min Daylight min level: 5 lux/15 lux/30 lux/50 lux/100 lux/150 lux/Disable
OS2	Bi-Level Detection Area : 100% Hold Time : 20 min Stand-by Dim Level : 50% Daylight min level : Disable	Internal High Frequency - ON/OFF, Bi-Level, Tri-Level, Hold-Off daylight level 120-277 V, Max 50' ceiling heights, -35°C to 70°C	Detection Area: 10%/50%/75%/100% Hold Time: 5s/30s/90s/3 min/20 min/+∞ Stand-by Dim Level: 10%/20%/30%/50% Stand-by Period: 0s/5s/5 min/10 min/30 min/1h/Disable Daylight min level: 2 lux/5 lux/10 lux/25 lux/50 lux/100 lux/Disable